



**BUREAU
VERITAS**

Certificate of compliance

Applicant: SolarEdge Technologies Ltd.
1 HaMada Street
Herzeliya 4673335
Israel

Product: Grid-tied photovoltaic inverter

Model: SE10K

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with IEC 61727:2004 and IEC62116:2014 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

IEC 61727:2004

Photovoltaic (PV) systems – Characteristics of the utility interface

IEC 62116:2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

IEEE 1547:2003, IEEE 1547.1:2005 (harmonics, d.c.-injection, voltage and frequency disconnection, reconnection)

IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems

The following deviations for Thailand were applied according to the Provincial Electricity Authority's Regulation on the Power Network System Interconnection Code B.E.2559 (2016) for plants till 500kW:

under voltage limit (level 1):	198,0V
under voltage limit (level 2):	110,0V
over voltage limit (level 1):	242,0V
overvoltage limit (level 2):	264,0V
lower frequency limit:	47,0Hz
upper frequency limit:	52,0Hz
loss of main detection limit:	1s

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 10TH0222-IEC61727_PEA_1

Certificate number: U17-0264

Date of issue: 2017-06-23



Certification body

Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065

